

■焼却炉排ガスCO濃度等測定結果

| 試料採取日 | 結果が得られた日 | 煙突 | CO |
|------------|------------|----|-----|
| | | | ppm |
| 2023/12/14 | 2023/12/20 | D | 0 |
| 2023/10/3 | 2023/10/11 | D | 0 |
| 2023/9/19 | 2023/10/5 | D | 0 |
| 2023/9/6 | 2023/9/21 | B | 0 |
| 2023/9/6 | 2023/9/20 | B | 0 |
| 2023/8/1 | 2023/8/7 | D | 0 |
| 2023/6/1 | 2023/6/8 | D | 0 |
| 2023/4/26 | 2023/5/9 | B | 0 |
| 2023/4/6 | 2023/4/12 | D | 0 |
| 2023/3/8 | 2023/3/16 | D | 0 |
| 2023/2/23 | 2023/3/2 | D | 0 |
| 2023/2/9 | 2023/2/20 | D | 0 |
| 2022/12/15 | 2022/12/22 | D | 0 |
| 2022/11/2 | 2022/11/10 | B | 0 |
| 2022/10/12 | 2022/10/18 | D | 0 |
| 2022/9/7 | 2022/9/27 | B | 0 |
| 2022/8/30 | 2022/9/6 | D | 0 |
| 2022/7/14 | 2022/7/21 | D | 0 |
| 2022/6/22 | 2022/6/27 | D | 0 |
| 2022/5/11 | 2022/5/19 | D | 0 |
| 2022/4/12 | 2022/4/19 | B | 0 |
| 2022/4/8 | 2022/4/14 | D | 0 |
| 2022/3/4 | 2022/3/16 | D | 0 |
| 2021/11/30 | 2021/12/20 | B | 0 |
| 2021/6/8 | 2021/6/11 | B | 0 |
| 2020/12/11 | 2020/12/18 | B | 0 |
| 2020/8/28 | 2020/9/8 | B | 0 |
| 2020/3/31 | 2020/4/8 | B | 0 |
| 2020/3/31 | 2020/4/16 | B | - |
| 2019/11/28 | 2019/12/6 | A | 0 |
| 2019/11/28 | 2019/12/13 | A | - |
| 2019/11/15 | 2019/11/27 | C | 0 |
| 2019/11/15 | 2019/11/27 | C | - |
| 2019/4/4 | 2019/4/12 | A | 8 |
| 2018/10/30 | 2018/11/7 | A | 0 |
| 2018/5/31 | 2018/6/20 | C | - |
| 2018/5/31 | 2018/6/20 | A | - |
| 2018/5/31 | 2018/6/20 | A | 0 |
| 2017/6/29 | 2017/7/12 | C | - |
| 2017/6/29 | 2017/7/12 | A | - |
| 2017/6/29 | 2017/7/12 | C | 0 |
| 2017/6/29 | 2017/7/12 | A | 0 |
| 2017/1/31 | 2017/2/16 | A | 0 |
| 2016/9/30 | 2016/10/12 | A | - |
| 2016/9/30 | 2016/10/12 | C | - |
| 2016/9/30 | 2016/10/12 | A | 0 |
| 2016/9/30 | 2016/10/12 | C | 0 |

■焼却ガス温度

| 測定結果を得られた年月日 | 燃焼室中の燃焼ガスの温度 | 集じん器に流入する燃焼ガスの温度 | CO |
|--------------|--------------|------------------|------|
| | | | ppm |
| 2023/12 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/11 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/10 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/9 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/8 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/7 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/6 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/5 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/4 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/3 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/2 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2023/1 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/12 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/11 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/10 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/9 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/8 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/7 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/6 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/5 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/4 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/3 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/2 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2022/1 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/12 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/11 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/10 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/9 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/8 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/7 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/6 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/5 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/4 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/3 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/2 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2021/1 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/12 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/11 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/10 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/9 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/8 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/7 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/6 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/5 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/4 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/3 | 970°C~1000°C | 170°C~200°C | 0~10 |
| 2020/2 | 970°C~1000°C | 170°C~200°C | 0~10 |